

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

May 5, 2016

Mr. Robert Buser
Ulster County Buildings & Grounds
313 Shamrock Lane
Kingston, NY 12401

Dear Mr. Buser,

The following are results of the analyses performed on water samples from **Ulster Co. Buildings & Grounds** received at the laboratory 04/14/16.

Date/Time Collected: 04/14/16 7:14am-3:44pm
Collected By: Labworks - DD
Date/Time Received: 04/14/16 5:00pm
Secondary Lab IDs: UC16765-93

Sample ID	LOCATION	METHOD EPA 200.8	RESULTS	ACTION LEVEL
04141612	Family Court 16-18 Lucas Ave., Kingston Men's bathroom	Lead	0.18 mg/L X	0.015 mg/L
04141613	Board of Elections 284 Wall St., Kingston Men's room sink	Lead	0.0062 mg/L	0.015 mg/L
04141614	Public Defenders Office 280 Wall St., Kingston Men's room sink	Lead	0.12 mg/L X	0.015 mg/L
04141615	County Court House 285 Wall St., Kingston Annex 1 st floor	Lead	0.037 mg/L X	0.015 mg/L
04141616	Persen House 74 John St., Kingston Rest room sink	Lead	<0.001 mg/L	0.015 mg/L
04141617	Carr Bldg., Crime Victims 1 Pearl St., Kingston Sink 1 st rest room	Lead	0.015 mg/L X	0.015 mg/L
04141618	Dept. of Environment 17 Pearl St., Kingston Rest room sink - cold	Lead	0.0028 mg/L	0.015 mg/L

ENVIRONMENTAL LABWORKS, INC.

Ulster Co. Buildings & Grounds - 04141637

Sample ID	LOCATION	METHOD EPA 200.8	RESULTS	ACTION LEVEL
04141619	UC Office Bldg 244 Fair St., Kingston Rest room 1	Lead	0.60 mg/L X	0.015 mg/L
04141620	Public Health Dept Willow Park 230 Aaron Court, Kingston Lab sink	Lead	0.02 mg/L X	0.015 mg/L
04141621	Probation Dept. 733 Broadway, Kingston Locker room sink	Lead	0.18 mg/L X	0.015 mg/L
04141622-1	Mental Health Dept. GH 239 Golden Hill, Kingston Water fountain	Lead	<0.001 mg/L	0.015 mg/L
04141622-2	Mental Health Dept. GH 239 Golden Hill, Kingston Men's room sink	Lead	0.046 mg/L X	0.015 mg/L
04141623	Emergency Mgmt E-911 238 Golden Hill, Kingston 911 Bathroom	Lead	0.015 mg/L X	0.015 mg/L
04141624	UC Area Transit 1 Donny Circle, Kingston Men's bathroom sink	Lead	0.091 mg/L X	0.015 mg/L
04141625	Old Jail 61 Golden Hill, Kingston Parole rest room	Lead	0.018 mg/L X	0.015 mg/L
04141626	CCP (old) Probation 61 Golden Hill, Kingston Men's rest room	Lead	0.077 mg/L X	0.015 mg/L
04141627	Jail - Old Storage Garage 61 Golden Hill, Kingston Bathroom sink	Lead	0.0013 mg/L	0.015 mg/L
04141628	Tourism Heritage Center 20 Broadway, Kingston Ladies Room sink	Lead	0.016 mg/L X	0.015 mg/L

ENVIRONMENTAL LABWORKS, INC.

Ulster Co. Buildings & Grounds - 04141637

Sample ID	LOCATION	METHOD EPA 200.8	RESULTS	ACTION LEVEL
04141629	Veterans Transitional Housing 67 Wurts St., Kingston Bathroom 1 st floor sink	Lead	0.0098 mg/L	0.015 mg/L
04141630	UCCC Kingston Center 94 Mary's Ave., Kingston B&G sink	Lead	0.014 mg/L	0.015 mg/L
04141631	Central Auto 125 Maxwell Lane, Kingston Outside Hose Spigot	Lead	0.0035 mg/L	0.015 mg/L
04141632	Public Works Resnick Bldg 313 Shamrock Lane, Kingston Ground floor water fountain	Lead	<0.001 mg/L	0.015 mg/L
04141633	Public Works Quarry 317 Shamrock Lane, Kingston Dispatch	Lead	0.022 mg/L X	0.015 mg/L
04141634-1	Development Court Kingston Dist system 1	Lead	0.25 mg/L X	0.015 mg/L
04141634-2	Development Court Kingston Dist system 2	Lead	0.025 mg/L X	0.015 mg/L
04141634-3	Development Court Kingston Dist system 3	Lead	0.79 mg/L X	0.015 mg/L
04141635	Records Storage/Hall of Records 300 Foxhall Ave, Kingston Men's room sink	Lead	0.061 mg/L X	0.015 mg/L
04141636	Information Services 25 South Manor, Kingston Men's room	Lead	0.60 mg/L X	0.015 mg/L
04141637	Social Services Child Advocacy 21 O'Neil St., Kingston Sink	Lead	0.33 mg/L X	0.015 mg/L

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

Ulster Co. Buildings & Grounds - 04141637

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions, or require any additional services, please do not hesitate to call us at 845-236-7823.

Thank you,

Trudie Lund for
Anthony J. Falco
Laboratory Director