

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

May 12, 2016

Mr. Robert Buser
Ulster County Buildings & Grounds
313 Shamrock Lane
Kingston, NY 12401

Dear Mr. Buser,

The following are results of the analyses performed on a water sample from **Ulster Co. Buildings & Grounds** received at the laboratory 04/28/16.

Date/Time Collected: 04/28/16 2:25pm
Collected By: Labworks - AJF
Date/Time Received: 04/28/16 4:15pm
Secondary Lab ID: UC16885

Sample ID	LOCATION	METHOD EPA 200.8	RESULTS	ACTION LEVEL
04281615	Trudy Resnick Bldg. 50 Center St., Ellenville Room B19 sink	Lead	0.0022 mg/L	0.015 mg/L

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions, or require any additional services, please do not hesitate to call us at 845-236-7823.

Thank you,

Trudie Lund for
Anthony J. Falco
Laboratory Director